

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1551

Dated: 30/04/2026

It is certified that an inspection team headed by Sudhir Chaudhary बसाय वै. जावि

(Name of Officers with designation) from P.H. Engg. Lab. Narnaul PHED

inspected the Suraj Sr. Sec. School, Bucholi, Mahendargarh

(Name & Address of the school) on 03.04.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1551 dated 30.04.2026

of Suraj Sr. Sec. School, Bucholi (PHED Lab) certified that

the Suraj Sr. Sec. School, Bucholi, Mahendargarh (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 31.03.2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

P.H. Engg. Lab Narnaul

To

Suraj Sr. Sec. School
Bucholi, Mahendargarh
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Handrapal
PRINCIPAL
SURAJ SR. SEC. SCHOOL
Bucholi, Mahendargarh
Haryana (India) Pin Code - 123034
SCHOOL CODE : 40403



**DISTRICT WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
NARNAUL, HARYANA**



TEST REPORT

Test Report No.: -MHD/00196/4/2026	Issue Date: - 30/04/2026
Issued to: - Principal	Location: - Own T/W
Test ID.: - 552463	Collected by: - Ravinder
Sample Type: - Chemical	Sample collected on: - 01/04/2026
Address: Suraj Sr. Sec. School Bucholi, Mahendergarh	Sample received on: - 01/04/2026
	Sample Quantity: -1 Ltr.

Test Result

Test started on: - 03/04/2026				Test completed on: - 03/04/2026		
Sr. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012RA 2018	
					Acceptable	Permissible Limit
1	Turbidity	0.19	NTU	APHA 2130 B	1 NTU	5 NTU
2	Taste	Agreeable	---	IS 3025 (Part-8), APHA 2160 C	Agreeable	Agreeable
3	Odour	Agreeable	---	IS 3025 (Part-5), APHA 2150 B	Agreeable	Agreeable
4	Colour	.05	Hazen Unit	APHA 2120 B, C	5 Hazen Unit	15 Hazen Unit
5	Total Dissolve Solids @ 180 ° C	180	mg/l	APHA 2540 C	500 mg/l	2000 mg/l
6	Total Hardness (as CaCO3)	110	mg/l	APHA 2340 C	200 mg/l	600 mg/l
7	Calcium as (Ca)	16.03	mg/l	APHA 3500-Ca B	75 mg/l	200 mg/l
8	Magnesium (Mg)	17.01	mg/l	APHA 3500-Mg B	30 mg/l	100 mg/l
9	Total Alkalinity (as CaCO3)	140	mg/l	APHA 2320 B	200 mg/l	600 mg/l
10	Chlorides (as Cl)	124.93	mg/l	APHA 4500-Cl B	250 mg/l	1000 mg/l
11	Sulphate as (SO4)	24	mg/l	APHA 4500-SO4 D & E	200 mg/l	400 mg/l
12	Fluoride as (F)	0.24	mg/l	APHA 4500-F D	1.0 mg/l	1.5 mg/l
13	Iron as (Fe)	0.10	mg/l	APHA 3500-Fe B	1.0 mg/l	No Relaxation
14	Nitrate as (NO3)	1.3	mg/l	APHA 4500-NO3 B	45 mg/l	No Relaxation
15	pH @ 25 ° C	7.19	---	APHA 4500-H+ B	6.5-8.5	No Relaxation
16.	Free Residual Chlorine	Nil			0.2 mg/lit	1.0 mg/lit

Opinion: The parameter tested at Sr.No. 1-16 in the test report meets the requirement of IS 10500:2012 (RA- 2018). The above water sample of sample descriptions chemically Fit on the Above Parameters

Specific contractual notes: -

- ♦ The results given above are related to the sample as received and tested in PHED Lab Narnaul.
- ♦ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab Narnaul.
- ♦ The test report can't be used for any publicity or any legal purpose.
- ♦ The samples received shall be destroyed after 7 Days from the date of issue of the certificate.
- ♦ Reliability of water sample lies with sender/collector of water sample.

Reviewed by: Technical Manager

[Signature]

PRINCIPAL
SURAJ SR. SEC. SCHOOL
Bucholi, Mahendergarh
Haryana (India) Pin Code - 123034
PHONE CODE : 40499

-----End of Report-----

[Signature]
Authorised Signatory
Quality Manager
30.04.20.

To,

The Principal
Suraj Sr. Sec. School
Bucholi M/Garh

Memo No. 1554

Date: 30.04.2026

Subject: - Bacteriological Examination Report of Water Sample.

Reference: - Dated: 01.04.2026

Person who collected Samples: - Ravinder

Samples Collection Date: - 01.04.2026


Sample Receipt Date: - 01.04.2026

Sr. No.	Sample ID	Source of Sample	No. of Coliforms	E-Coli	Result
1.	MHD/00198/04/2026	Own T/W	0	0	Fit

Serial Number 1 Water Sample is Bacteriological fit

Reliability of Water Sample lies with sender/ collector of water sample.


PRINCIPAL
SURAJ SR. SEC. SCHOOL
Bucholi, Mahendergarh
Haryana (India) Pin Code - 123034
SCHOOL CODE : 40499


Authorized Signatory/ Incharge/ QM
30.04.26.



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,
NARNAUL



To,

The Principal
Suraj Sr. Sec. School
Bucholi, M/Garh


Memo No. 1551

Date: 30/04/2026

Subject: Bacteriological & Chemical analysis report of water samples.

This office is in receipt of 02 nos. water samples received in this office your letter no. 249 dated 01.04.2026. Please find enclosed herewith the Bacteriological analysis report of water samples.


PRINCIPAL
SURAJ SR. SEC. SCHOOL
Bucholi, Mahendergarh
Haryana (India) Pin Code - 123034
SCHOOL CODE - 40499


Authorized Signatory/ Incharge/ QM
30.04.26.